



ફોન : ૨૪૩૮૪૨ / ૨૪૩૮૪૩ / ૨૪૩૮૪૪

ફાયર બ્રિગેડ : ૨૪૩૧૦૧

ફેક્સ નં.: ૦૨૬૯૨-૨૪૪૮૮૧

## આણંદ નગરપાલિકા, આણંદ.

મહાત્મા ગાંધી માર્ગ, આણંદ - ૩૮૮ ૦૦૧.

(જિલ્લો આણંદ)



જાવક નંબર એ.એમ/ફા.પ/૦૩૮ તા. ૦૧/૦૨/૨૦૨૦

To,  
Academic Heights Public School,  
B/h High School,  
Kasor-Ajarpura-388310.  
Di & Ta: Anand.

### To whomsoever it may concern

This is to certify that Academic Heights Public School having ground +2 floors building located at B/h High School, Kasor, Ajarpura, Anand, Survey No: 1084 had applied for Fire Safety Certificate and was inspected today and fire risk were observed were very low category and evacuation in case of emergency cannot be a problem.


The school has fulfilled all the required Fire Safety measures therefore the **No Objection Certificate (NOC)** is given with the below conditions

1. Wet Riser System should be always kept on and active.
2. All fire safety instruments should be inspected and tested and seen that it is under working condition. The report of this testing and inspection should be reported in written format and kept for future evidence.
3. All fire extinguishers kept in a space where it can be reached very easily in case of any emergency.
4. Underground water tank which is to be used for extinguishing fire should be always filled with water and this water should not be used for any other use at all.

5. All the safety measures rules which will be formulated even in future should be followed strictly.
6. The ways and space as shown in the map for the fire brigade vehicles to reach the school should be always maintained and kept free. In case of emergency if the fire operation is failed due to the blockage of the ways, the management will be responsible for the disaster.
7. All the escape/exit routes shall not be kept locked/blocked or encroached.
8. Fire extinguishers should be regularly refilled and tested by District Fire officer every year.
9. All the Fire protection arrangement should be maintained in good repair and a security person should be appointed to maintain all those instruments.
10. The management is responsible to maintain all Fire Safety Measures in a good and working condition.
11. All the Fire Safety Measures observed during the inspections should not be removed or replaced.
12. If the management does not follow all the fire safety measures they can be legally scrutinized and given a notice.
13. NOC of Fire Safety should be renewed every year.
14. The school will abide by the rules and regulation act of GDCR-2013, Rules and Regulations of 2014 and 2016.
15. This NOC is valid to 07/07/2021.



Copy forwarded below same ,

  
Fire Superintendent  
Anand Nagar Palika  
Anand

1. Copy submitted to District Avkuda office , Anand
2. Copy submitted to Regional Fire Officer, Vadodara